


Airborne sound absorption measured in a reverberation chamber.
BS EN ISO 354:2003

Customer: Woolly Shepherd

Construction tested

Suspended Rectangles

Frequency Hz	Absorption $A_{obj} m^2$
100	0.29
125	0.30
160	0.40
200	0.47
250	0.86
315	1.09
400	1.33
500	1.56
630	1.64
800	1.70
1000	1.77
1250	1.75
1600	1.72
2000	1.73
2500	1.71
3150	1.71
4000	1.67
5000	1.61



Test Standard: BS EN ISO 354

Project No: 10232

UNIVERSITY OF
Southampton

ISVR Consulting

University of Southampton
Highfield, Southampton

Tested by: J.Fithyan
Test date: 15/12/2016